



University of  
**Salford**  
MANCHESTER

# Assessing the performance of domestic heating controls in a whole house test facility

Fitton, R, Swan, W, Benjaber, MAA, Hughes, T and Todd, S  
<http://dx.doi.org/10.1177/0143624416634070>

<b>Title</b>	Assessing the performance of domestic heating controls in a whole house test facility
<b>Authors</b>	Fitton, R, Swan, W, Benjaber, MAA, Hughes, T and Todd, S
<b>Type</b>	Article
<b>URL</b>	This version is available at: <a href="http://usir.salford.ac.uk/id/eprint/38003/">http://usir.salford.ac.uk/id/eprint/38003/</a>
<b>Published Date</b>	2016

USIR is a digital collection of the research output of the University of Salford. Where copyright permits, full text material held in the repository is made freely available online and can be read, downloaded and copied for non-commercial private study or research purposes. Please check the manuscript for any further copyright restrictions.

For more information, including our policy and submission procedure, please contact the Repository Team at: [usir@salford.ac.uk](mailto:usir@salford.ac.uk).

**Table 3.** Temperatures during Test 2.

	Bathroom	Bedroom 1	Bedroom 2	Hall	Kitchen	Living room
Room temperatures between 6:30-9:00 at geometric centre						
Average Temp °C	25.44	24.47	24.44	25.44	22.63	20.29
Max Temp °C	27.4	27.2	26.8	26.9	25.3	22.7
Min Temp °C	19.1	18.4	19	22.3	16.3	14.3
Room temperatures between 15:30-23:00 at geometric centre						
Average Temp °C	27.15	25.83	25.84	26.29	24.20	21.43
Max Temp °C	29.3	27.6	27.7	27.9	26	23
Min Temp °C	18.7	17.9	18.5	21.7	16	14