



University of  
**Salford**  
MANCHESTER

# Assessing the performance of domestic heating controls in a whole house test facility

Fitton, R, Swan, W, Benjaber, MAA, Hughes, T and Todd, S

<http://dx.doi.org/10.1177/0143624416634070>

<b>Title</b>	Assessing the performance of domestic heating controls in a whole house test facility
<b>Authors</b>	Fitton, R, Swan, W, Benjaber, MAA, Hughes, T and Todd, S
<b>Type</b>	Article
<b>URL</b>	This version is available at: <a href="http://usir.salford.ac.uk/id/eprint/38003/">http://usir.salford.ac.uk/id/eprint/38003/</a>
<b>Published Date</b>	2016

USIR is a digital collection of the research output of the University of Salford. Where copyright permits, full text material held in the repository is made freely available online and can be read, downloaded and copied for non-commercial private study or research purposes. Please check the manuscript for any further copyright restrictions.

For more information, including our policy and submission procedure, please contact the Repository Team at: [usir@salford.ac.uk](mailto:usir@salford.ac.uk).

**Table 5.** Gas and electricity consumption during the tests.

Tests	Gas Used				Electricity Used			Totals		
	m <sup>3</sup>	kWh <sup>*1</sup>	£ <sup>*2</sup>	kgCO <sub>2</sub> <sup>*3</sup>	kWh	£ <sup>*2</sup>	kgCO <sub>2</sub> <sup>*3</sup>	kWh	£ <sup>*2</sup>	kgCO <sub>2</sub> <sup>*3</sup>
1	10.72	121.8	£5.20	22.558	0.83	£0.11	0.431907	122.63	£5.31	22.99047
2	9.42	107.4	£4.57	19.824	0.75	£0.10	0.390277	107.79	£4.67	20.21514
3	6.28	71.36	£3.05	13.601	0.74	£0.09	0.385073	72.1	£3.15	13.60165

\*1 – Calculated using [http://www.energylinx.co.uk/gas\\_meter\\_conversion\\_meters.html](http://www.energylinx.co.uk/gas_meter_conversion_meters.html) with default settings (Correction Factor = 1.02264, Calorific Value = 40.0)

\*2 – Based on British Gas Clear & Simple cash/card payment (4.274p per kWh gas, 12.797p per kWh electric) not including standing charge (24.439p per day gas and 15.979p per day electric) – Prices taken on 07/05/2013 from <http://www.britishgas.co.uk/products-and-services/gas-and-electricity/our-tariffs/clear-and-simple-rates.html>

\*3 – Calculated using DECC:Climate Change Agreements Interim Guidance (Version 1.1), GP 3.5 Conversion Factors & Procedures, 28/09/2012. Recovered on 10/10/2012 from <http://www.decc.gov.uk/assets/decc/11/cutting-emissions/cca/6112-cca-interim-guidance-gp3-5.pdf>